

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 04/ जि.प्र. / लो.स्वा.ओं. / उपरकंड / शिवपुरी

Dated: 13/06/2025

It is certified that an inspection team headed by Rajeev Bhatia from Shivpuri PHED, Dist Shivpuri (MP) inspected the **KHEDAPATI SIGNATUTRE INTERNATION SCHOOL, NEAR ABDUL COLONY, VILLAGE SINGHNIWAS, TEH. AND DIST. SHIVPURI(M.P.)** on 18.06.2025 and on the basis of Water Test Report (Attached) bearing no. 80/1 dated 11/06/25 of (PHED Lab) certified that the **KHEDAPATI SIGNATUTRE INTERNATION SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17.06.202617.06.2026

Quality manager
D.W.T.L. Shivpuri
(M.P.)


Signature with Seal: Rajeev Bhatia 19/06/25Name: Rajeev BhatiaDesignation: Quality managerD.W.T.L. Shivpuri
(M.P.)

Name & Address of the Office / Department:

Issued To
KHEDAPATI SIGNATUTRE INTERNATION SCHOOL
NEAR ABDUL COLONY, VILLAGE SINGHNIWAS
TEH. AND DIST. SHIVPURI (M.P.)


Headmaster

Khedapati Signature International School
Shivpuri (M.P.) Code-PS121958



PRESIDENT / SECRETARY / TREASURER
SHRI KHEDAPATI-JI EDUCATION
AND SOCIAL WELFARE SOCIETY
No. 02/41/01/26293/23

Health Engineering Department Water Testing Laboratory District Shivpuri (M.P.)

Status of Sample	Chemical /Bacteriological Test	Unique Identification No.	80/1
Sender's name	By- Khedapati Signature International School Near Abdul Kalam Colony Shivpuri	Sender's letter no.	Q
Sender's address	By- Khedapati Signature International School Near Abdul Kalam Colony Shivpuri	Sender's letter date	26/05/2025
		Start Date Of Analysis	10/06/2025
Quantity of Sample	1 Ltr.	Receipt No.	02
Sample Collected by	School Staff	End Date Of Analysis	11/06/2025


Sample details:


S.No	District	Block	Village	Location	source
1	Shivpuri	Shivpuri	Shivpuri	By- Khedapati Signature International School Near Abdul Kalam Colony Shivpuri	B.W

Physical/ Chemical /Bacteriological Test Report With Details of Parameters Their Test Methods, Units and Specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS-10500:2012 & Reaffirmed in Sep. 2018		Test Result								
				Requirement (Desirable Limit)	Permissible Limit in the absence of Alternate Source	Sample Numbers								
						1	2	3	4	5	6	7		
1	2	3	4	5	6	7								
1	Turbidity	BIS :3025 Part 10	NTU	1	5	3.7								
2	pH	BIS :3025 Part 11	pH scale	6.5to8.5	<6.5to9.2>	7.2								
3	TDS	BIS :3025 Part 16		500	2000	468								
4	Total Hardness as CaCO ₃	BIS :3025 Part 21	mg/l	200	600	226								
5	Total Alkalinity as CaCO ₃	BIS :3025 Part 23	mg/l	200	600	399								
6	Residual chlorine	BIS :3025 Part 26	ppm	0.2	>1.0	Nil								
7	Chloride as Cl	BIS :3025 Part 32	mg/l	250	1000	23								
8	Calcium as Ca ⁺⁺	BIS :3025 Part 40	mg/l	75	200	59								
9	Magnesium as Mg	BIS :3025 Part 46	mg/l	30	100	18								
10	Iron as Fe ⁺⁺	BIS :3025 Part 53	mg/l	0.3	1.0	Nil								
11	Nitrate as No ₃	BIS :3025 Part 34	mg/l	45	45	1.0								
12	Fluoride as F ⁻	BIS :3025 Part 60	mg/l	1.0	1.5	0								
13	Total coliform MPN/100ml	standard method1992	MPN 100ml	zero	10	0								


Headmaster
 Khedapati Signature International School
 Shivpuri (M.P.) Code-PS121958


 Signature
 Authorized Signatory
 Quality Manager
 Shivpuri (M.P.)


PRESIDENT / SECRETARY / TREASURER
SHRI KHEDAPATI JI EDUCATION
AND SOCIAL WELFARE SOCIETY
 No. 02/41/01/26293/23